

LAKE ARROWHEAD COMMUNITY SERVICES DISTRICT

MEMORANDUM

DATE: June 27, 2017

TO: BOARD OF DIRECTORS
Lake Arrowhead Community Services District

FROM: 
MIKE BLACKWOOD, Field Operations Manager


CATHERINE CERRI, General Manager

SUBJECT: REPORTING TO LAHONTAN REGIONAL WATER
QUALITY CONTROL BOARD REGARDING CEASE AND
DESIST ORDER R6V-2013-022

A. RECOMMENDATION

This is an informational item only.

B. REASON FOR RECOMMENDATION

This is an informational item only.

C. BACKGROUND INFORMATION

The Lake Arrowhead Community Services District (“LACSD” or “District”) has historically had high levels of inflow into the collection system during storm events. Old infrastructure and mountainous terrain create a challenge during heavy precipitation. In 2013, the Lahontan Regional Water Quality Control Board (“LRWQCB”) issued a cease and desist order (“CDO”) requiring LACSD to reduce inflow and infiltration (“I/I”) into the collection system to avoid surges and unauthorized discharges at the wastewater treatment plant.

LACSD agrees that a reduction in I/I is in the best interest of the District, the community and the environment. The CDO specified milestones to be completed which included a study of the different basins to identify the largest inflows. Sewer monitors were installed and analyzed from 2012 to 2017. While there were several years of drought, there was enough data to identify certain areas as high or low inflow. A map showing these areas is attached. Analysis of the system is ongoing along with continual CCTV inspections and smoke testing.

The most recent year’s data included closer to normal levels of precipitation. Staff utilized this information to conduct a Cost Effectiveness Analysis which ranked the

various monitored areas by volume of flow, wet to dry ratio and the cost effectiveness of removing the I/I in that area. The results are attached.

On June 21, 2017, District staff met with LRWQCB regarding the required milestones, ongoing reporting and next steps. LACSD staff discussed the sewer model requirement in the CDO and LRWQCB staff concurred that CDO compliance could be demonstrated using sewer flow monitor data to the treatment plants but requested an additional meter on the intertie between Grass Valley Wastewater Treatment Plant and Willow Creek Wastewater Treatment Plant (“WCWWTP”) to show how the additional storage capacity at WCWWTP assists in avoiding an overflow. It was helpful to have Board approval for the sewer model in advance of the meeting. LRWQCB staff agreed that the funds could be better spent on updating and improving the GIS data. LACSD staff will confirm this in writing. LACSD staff also agreed to continue the sewer flow monitoring reporting.


D. FISCAL INFORMATION

This is an informational item only.



E. ATTACHMENTS


Excerpts from the June 15, 2017 CDO Report

Dry to Wet Flow Monitoring Ratios 2016-2017




Basin Ratios Parcels







Annual CCTV Locations



Annual Smoke Testing Locations

GRASS VALLEY AND WILLOW CREEK TREATMENT PLANT INFLOW METER GRAPHS



**Summary Table of Inflow
Cost Effective Analysis For Rehabilitation**

Exhibit 7

1

Basin 1: Grass Valley, Twin Peaks

| Sub-Basin | Monitor | Ranking | Yrs Monitored (FYE) | Wet to Dry Ratio | Sewer Length ft | Avg Dry Flow MGD | Avg Wet Flow MGD | Peak Inflow GPD | Removable Reduction Factor | Removable Inflow GPD | Treatment & Transport Cost \$ | Type of Defect | Rehab Method | Rehab Life Yrs | Rehab Cost \$ | Cost Effective >1 | Comments |
|-------------|------------------|----------|---------------------|------------------|-----------------|------------------|------------------|-----------------|----------------------------|----------------------|-------------------------------|----------------|--------------|----------------|---------------|---------------------|----------|
| 1-01 | | <u>5</u> | <u>13 - 17</u> | | | | | | | | | | | | | | |
| | Brentwood | low | 13 - 16 | 1.79 | 7,720 | 0.007 | 0.012 | 5,400 | 40% | 2,160 | 3,797 | | Repair | 10 | 15,440 | 0.25 | (1) |
| | Brentwood North | low | 13 | 1.96 | 7,623 | 0.006 | 0.011 | 5,400 | 40% | 2,160 | 3,797 | | Repair | 10 | 15,246 | 0.25 | |
| | Trinity | low | 13 | 1.14 | 6,880 | 0.005 | 0.006 | 700 | 40% | 280 | 492 | | Repair | 10 | 13,760 | 0.04 | |
| | Station 33 | low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| | Brentwood A | med | 17 | 2.22 | 42,899 | 0.036 | 0.080 | 44,000 | 40% | 17,600 | 30,936 | | Repair | 10 | 85,798 | 0.36 | (2) |
| 1-02 | | <u>1</u> | <u>13, 17</u> | | | | | | | | | | | | | | |
| | Golf Course West | high | 13 | 5.00 | 16,181 | 0.010 | 0.050 | 40,000 | 40% | 16,000 | 28,123 | | Repair | 10 | 32,362 | 0.87 | |
| | Station 33 | low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| | Brentwood A | med | 17 | 2.22 | 42,899 | 0.036 | 0.080 | 44,000 | 40% | 17,600 | 30,936 | | Repair | 10 | 85,798 | 0.36 | (3) |
| 1-03 | | <u>3</u> | <u>13</u> | | | | | | | | | | | | | | |
| | Station 33 | low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| | Golf Course East | med | 13 | 1.90 | 10,793 | 0.021 | 0.040 | 19,000 | 40% | 7,600 | 13,359 | | Repair | 10 | 21,586 | 0.62 | |
| 1-04 | | <u>4</u> | <u>13, 17</u> | | | | | | | | | | | | | | |
| | Golf Course East | med | 13 | 1.90 | 10,793 | 0.021 | 0.040 | 19,000 | 40% | 7,600 | 13,359 | | Repair | 10 | 21,586 | 0.62 | |
| | Alpine Camp | med | 13 | 2.20 | 14,766 | 0.010 | 0.022 | 12,000 | 40% | 4,800 | 8,437 | | Repair | 10 | 29,532 | 0.29 | |
| | Fairway | low | 13 | 1.40 | 8,411 | 0.030 | 0.042 | 12,000 | 40% | 4,800 | 8,437 | | Repair | 10 | 16,822 | 0.50 | |
| | Club House East | low | 13 - 17 | 1.24 | 30,200 | 0.030 | 0.038 | 7,330 | 30% | 2,199 | 3,865 | | Repair | 10 | 60,400 | 0.06 | (4) |
| | Station 33 | low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| | Brentwood B | low | 17 | 1.63 | 41,631 | 0.008 | 0.013 | 5,000 | 40% | 2,000 | 3,515 | | Repair | 10 | 83,262 | 0.04 | (5) |
| 1-05 | | <u>6</u> | <u>13 - 17</u> | | | | | | | | | | | | | | |
| | Station 33 | low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| | Club House West | low | 13 - 16 | 1.14 | 41,000 | 0.033 | 0.037 | 4,600 | 35% | 1,610 | 2,830 | | Repair | 10 | 82,000 | 0.03 | |
| 1-06 | | <u>2</u> | <u>13, 16</u> | | | | | | | | | | | | | | |
| | Daley Canyon | med | 13 | 2.00 | 27,143 | 0.015 | 0.030 | 15,000 | 30% | 4,500 | 7,910 | | Repair | 10 | 54,286 | 0.15 | |
| | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 322,099 | | Repair | 10 | 575,552 | 0.56 | |

Monitor covers multiple sub-basins

**Summary Table of Inflow
Cost Effective Analysis For Rehabilitation**

Exhibit 7

Basin 2: Blue Jay to Dam

| Sub-Basin | Monitor | Ranking | Yrs Monitored (FYE) | Wet to Dry Ratio | Sewer Length ft | Avg Dry Flow MGD | Avg Wet Flow MGD | Peak Inflow GPD | Removable Reduction Factor | Removable Inflow GPD | Treatment & Transport Cost \$ | Type of Defect | Rehab Method | Rehab Life Yrs | Rehab Cost \$ | Cost Effective ^{>1} | |
|-----------|------------------|---------|---------------------|------------------|-----------------|------------------|------------------|-----------------|----------------------------|----------------------|-------------------------------|----------------|--------------|----------------|---------------|---------------------------------|------|
| 2-01 | | XX | 13 - 16 | | | | | | | | | | | | | | |
| | BJ Trailer Park | high | 13 | 1.40 | 66,684 | 1.500 | 2.100 | 600,000 | 50% | 300,000 | 2,636,550 | | Slipline | 50 | 4,334,460 | 0.61 | (17) |
| | Arturos | low | 14 - 16 | 1.29 | 1,740 | 0.007 | 0.009 | 2,000 | 40% | 800 | 1,406 | | Repair | 10 | 3,480 | 0.40 | |
| | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 322,099 | | Repair | 10 | 575,552 | 0.56 | |
| 2-02 | | 3 | 14 - 17 | | | | | | | | | | | | | | |
| | Cedar Circle | high | 14 - 16 | 2.39 | 12,900 | 0.006 | 0.013 | 7,800 | 70% | 5,460 | 47,985 | | Replace | 50 | 1,290,000 | 0.04 | |
| | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 | |
| | Cedar Circle A | high | 17 | 3.33 | 4,381 | 0.003 | 0.010 | 7,000 | 70% | 4,900 | 43,064 | | Replace | 50 | 438,100 | 0.10 | |
| | Cedar Circle B | high | 17 | 2.73 | 6,586 | 0.005 | 0.013 | 8,337 | 70% | 5,836 | 51,289 | | Replace | 50 | 658,600 | 0.08 | |
| 2-03 | | 4 | 14 - 17 | | | | | | | | | | | | | | |
| | Rainbow Creek | low | 14 - 16 | 1.28 | 9,500 | 0.011 | 0.014 | 3,100 | 30% | 930 | 1,635 | | Repair | 10 | 19,000 | 0.09 | |
| | Cottage Grove Ck | med | 14 - 16 | 1.71 | 26,800 | 0.023 | 0.040 | 16,650 | 30% | 4,995 | 8,780 | | Repair | 10 | 53,600 | 0.16 | |
| | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 | |
| | Cottage Grove A | low | 17 | 1.67 | 11,180 | 0.004 | 0.006 | 2,400 | 35% | 840 | 1,476 | | Repair | 10 | 22,360 | 0.07 | |
| | Cottage Grove B | low | 17 | 1.21 | 9,246 | 0.026 | 0.032 | 5,530 | 35% | 1,936 | 3,402 | | Repair | 10 | 18,492 | 0.18 | (6) |
| 2-04 | | XX | 16 - 17 | | | | | | | | | | | | | | |
| | Beaver | med | 16 - 17 | 1.79 | 262,293 | 0.273 | 0.488 | 215,000 | 50% | 107,500 | 188,953 | | Repair | 10 | 524,586 | 0.36 | |
| 2-05 | | 7 | 14 - 16 | | | | | | | | | | | | | | |
| | Rainbow Creek | low | 14 - 16 | 1.28 | 9,500 | 0.011 | 0.014 | 3,100 | 30% | 930 | 1,635 | | Repair | 10 | 19,000 | 0.09 | |
| | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 | |
| 2-06 | | 6 | 14 - 17 | | | | | | | | | | | | | | |
| | Chalets | low | 14 - 17 | 1.49 | 50,255 | 0.042 | 0.063 | 20,750 | 30% | 6,225 | 10,942 | | Repair | 10 | 100,510 | 0.11 | (7) |
| | Beaver | med | 16 - 17 | 1.79 | 262,293 | 0.273 | 0.488 | 215,000 | 50% | 107,500 | 188,953 | | Repair | 10 | 524,586 | 0.36 | |
| 2-07 | | 8 | 14 - 17 | | | | | | | | | | | | | | |
| | GTO | low | 14 - 16 | 1.29 | 13,700 | 0.005 | 0.007 | 1,500 | 30% | 450 | 791 | | Repair | 10 | 27,400 | 0.03 | |
| | Beaver | med | 16 - 17 | 1.79 | 262,293 | 0.273 | 0.488 | 215,000 | 50% | 107,500 | 188,953 | | Repair | 10 | 524,586 | 0.36 | |
| | GTO B | low | 17 | 1.22 | 7,023 | 0.002 | 0.002 | 330 | 30% | 99 | 174 | | Repair | 10 | 14,046 | 0.01 | (8) |

**Summary Table of Inflow
Cost Effective Analysis For Rehabilitation**

Exhibit 7

Basin 2: Blue Jay to Dam (continued)

| Sub-Basin | Monitor | Ranking | Yrs Monitored (FYE) | Wet to Dry Ratio | Sewer Length ft | Avg Dry Flow MGD | Avg Wet Flow MGD | Peak Inflow GPD | Removable Reduction Factor | Removable Inflow GPD | Treatment & Transport Cost \$ | Type of Defect | Rehab Method | Rehab Life Yrs | Rehab Cost \$ | Cost Effective ^{>1} | |
|-----------|-----------------|---------|---------------------|------------------|-----------------|------------------|------------------|-----------------|----------------------------|----------------------|-------------------------------|----------------|--------------|----------------|---------------|---------------------------------|------|
| 2-08 | | 2 | 14 - 17 | | | | | | | | | | | | | | |
| | Potomac Creek | low | 14 - 16 | 1.42 | 5,200 | 0.008 | 0.011 | 3,300 | 40% | 1,320 | 2,320 | | Repair | 10 | 10,400 | 0.22 | |
| | John Muir | high | 15 - 16 | 5.04 | 17,900 | 0.047 | 0.237 | 190,000 | 40% | 76,000 | 133,585 | | Repair | 10 | 35,800 | 3.73 | |
| | Beaver | med | 16 - 17 | 1.79 | 262,293 | 0.273 | 0.488 | 215,000 | 50% | 107,500 | 188,953 | | Repair | 10 | 524,586 | 0.36 | |
| | John Muir A | med | 17 | 1.98 | 15,351 | 0.011 | 0.021 | 10,330 | 40% | 4,132 | 7,263 | | Repair | 10 | 30,702 | 0.24 | |
| | John Muir B | low | 17 | 1.29 | 6,654 | 0.004 | 0.005 | 1,000 | 40% | 400 | 703 | | Repair | 10 | 13,308 | 0.05 | (9) |
| 2-09 | | 1 | 14 - 17 | | | | | | | | | | | | | | |
| | Emerald Bay | high | 14 - 16 | 1.57 | 69,900 | 0.008 | 0.013 | 4,700 | 50% | 2,350 | 20,653 | | Replace | 50 | 3,000,000 | 0.01 | (10) |
| | Beaver | med | 16 - 17 | 1.79 | 262,293 | 0.273 | 0.488 | 215,000 | 50% | 107,500 | 188,953 | | Repair | 10 | 524,586 | 0.36 | (11) |
| | Emerald Bay A | low | 17 | 1.27 | 27,189 | 0.007 | 0.009 | 2,000 | 30% | 600 | 1,055 | | Repair | 10 | 54,378 | 0.02 | |
| | Emerald Bay B | high | 17 | 2.13 | 25,037 | 0.053 | 0.112 | 59,400 | 70% | 41,580 | 365,426 | | Replace | 50 | 2,503,700 | 0.15 | (12) |
| 2-10 | | 5 | 14 - 17 | | | | | | | | | | | | | | |
| | Emerald Creek | low | 14 - 16 | 1.42 | 9,053 | 0.013 | 0.019 | 5,500 | 30% | 1,650 | 2,900 | | Repair | 10 | 18,106 | 0.16 | |
| | Beaver | med | 16 - 17 | 1.79 | 262,293 | 0.273 | 0.488 | 215,000 | 50% | 107,500 | 188,953 | | Repair | 10 | 524,586 | 0.36 | |
| | Emerald Bay A | low | 17 | 1.27 | 27,189 | 0.007 | 0.009 | 2,000 | 30% | 600 | 1,055 | | Repair | 10 | 54,378 | 0.02 | |
| | Emerald Creek B | low | 17 | 1.61 | 7,953 | 0.005 | 0.008 | 2,830 | 70% | 1,981 | 17,410 | | Replace | 50 | 795,300 | 0.02 | (13) |

Monitor covers multiple sub-basins

**Summary Table of Inflow
Cost Effective Analysis For Rehabilitation**

Exhibit 7

Basin 3: Northwest

| Sub-Basin | Monitor | Ranking | Yrs Monitored (FYE) | Wet to Dry Ratio | Sewer Length ft | Avg Dry Flow MGD | Avg Wet Flow MGD | Peak Inflow GPD | Removable Reduction Factor | Removable Inflow GPD | Treatment & Transport Cost \$ | Type of Defect | Rehab Method | Rehab Life Yrs | Rehab Cost \$ | Cost Effective >1 | |
|-----------|------------------|----------|---------------------|------------------|-----------------|------------------|------------------|-----------------|----------------------------|----------------------|-------------------------------|----------------|--------------|----------------|---------------|-------------------|------|
| 3-01 | TBD | | | | | | | | | | | | | | | | (19) |
| 3-02 | Station 14 | 3 med | 15 - 17 | 1.61 | 14,185 | 0.014 | 0.022 | 8,330 | 40% | 3,332 | 5,857 | | Repair | 10 | 28,370 | 0.21 | |
| 3-03 | Station 33 | low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| 3-04 | Station 33 | 1 low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| | Oakmont | high | 15 - 16 | 1.51 | 17,000 | 0.075 | 0.113 | 38,000 | 30% | 11,400 | 20,038 | | Repair | 10 | 34,000 | 0.59 | |
| 3-05 | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 | |
| 3-06 | Golf Course East | 2 med | 13 | 1.90 | 10,793 | 0.021 | 0.040 | 19,000 | 40% | 7,600 | 13,359 | | Repair | 10 | 21,586 | 0.62 | |
| | Station 33 | low | 13 | 1.33 | 315,339 | 0.045 | 0.060 | 15,000 | 50% | 7,500 | 13,183 | | Repair | 10 | 630,678 | 0.02 | (15) |
| | Golf Course Way | med | 15 | 8.40 | 10,600 | 0.005 | 0.042 | 37,000 | 25% | 9,250 | 16,259 | | Repair | 10 | 21,200 | 0.77 | |
| 3-07 | TBD | | | | | | | | | | | | | | | | (18) |
| 3-08 | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 | |
| 3-09 | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 | |
| 3-10 | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 | |

Monitor covers multiple sub-basins

**Summary Table of Inflow
Cost Effective Analysis For Rehabilitation**

Exhibit 7

Basin 4: Northeast

| Sub-Basin | Monitor | Ranking | Yrs Monitored (FYE) | Wet to Dry Ratio | Sewer Length ft | Avg Dry Flow MGD | Avg Wet Flow MGD | Peak Inflow GPD | Removable Reduction Factor | Removable Inflow GPD | Treatment & Transport Cost \$ | Type of Defect | Rehab Method | Rehab Life Yrs | Rehab Cost \$ | Cost Effective ¹ |
|-----------|----------------|---------|---------------------|------------------|-----------------|------------------|------------------|-----------------|----------------------------|----------------------|-------------------------------|----------------|--------------|----------------|---------------|-----------------------------|
| 4-01 | | 1 | | | | | | | | | | | | | | |
| | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 |
| | ALA Trail 43 | med | 16 | 1.86 | 25,900 | 0.035 | 0.065 | 30,000 | 40% | 12,000 | 21,092 | | Repair | 10 | 51,800 | 0.41 |
| | ALA Trail 43 A | med | 17 | 1.73 | 6,754 | 0.016 | 0.028 | 11,830 | 40% | 4,732 | 8,317 | | Repair | 10 | 13,508 | 0.62 |
| | ALA Trail 43 B | med | 17 | 1.93 | 18,986 | 0.010 | 0.020 | 9,500 | 40% | 3,800 | 6,679 | | Repair | 10 | 37,972 | 0.18 |
| 4-02 | TBD | | | | | | | | | | | | | | | (18) |
| 4-03 | Willow Creek | high | 16 - 17 | 1.84 | 287,776 | 0.437 | 0.803 | 366,500 | 50% | 183,250 | 1,610,493 | | Rehab | 50 | 2,158,320 | 0.75 |
| 4-04 | TBD | | | | | | | | 50% | | | | | | | (18) |
| 4-05 | Beaver | med | 16 - 17 | 1.79 | 262,293 | 0.273 | 0.488 | 215,000 | 50% | 107,500 | 188,953 | | Repair | 10 | 524,586 | 0.36 |
| 4-06 | | 2 | | | | | | | | | | | | | | |
| | SH 173 | med | 16 | 1.60 | 50,900 | 0.053 | 0.085 | 32,000 | 40% | 12,800 | 22,499 | | Repair | 10 | 101,800 | 0.22 |
| | SH 173 B | med | 17 | 2.14 | 17,476 | 0.005 | 0.010 | 5,500 | 40% | 2,200 | 3,867 | | Repair | 10 | 34,952 | 0.11 |
| 4-07 | | 3 | | | | | | | | | | | | | | |
| | SH 173 | med | 16 | 1.60 | 50,900 | 0.053 | 0.085 | 32,000 | 40% | 12,800 | 22,499 | | Repair | 10 | 101,800 | 0.22 |
| | SH 173 A | med | 17 | 1.61 | 16,549 | 0.016 | 0.025 | 9,500 | 40% | 3,800 | 6,679 | | Repair | 10 | 33,098 | 0.20 |

Monitor covers multiple sub-basins

**Summary Table of Inflow
Cost Effective Analysis For Rehabilitation**

Exhibit 7

Treatment Plants

| Sub-Basin | Monitor | Ranking | Yrs Monitored (FYE) | Wet to Dry Ratio | Sewer Length ft | Avg Dry Flow MGD | Avg Wet Flow MGD | Peak Inflow GPD | Removable Reduction Factor | Removable Inflow GPD | Treatment & Transport Cost \$ | Type of Defect | Rehab Method | Rehab Life Yrs | Rehab Cost \$ | Cost Effective ^{>1} | |
|-----------|-----------------|---------|---------------------|------------------|-----------------|------------------|------------------|-----------------|----------------------------|----------------------|-------------------------------|----------------|--------------|----------------|---------------|---------------------------------|------|
| N/A | Grass Valley TP | | 16 - 17 | 1.66 | 345,316 | 0.451 | 0.748 | 297,667 | 50% | 148,834 | 261,605 | | Repair | 10 | 690,632 | 0.38 | (14) |
| N/A | Willow Creek TP | | 16 - 17 | 1.72 | 688,289 | 1.080 | 1.855 | 775,163 | 50% | 387,582 | 3,406,260 | | Rehab | 50 | 5,162,168 | 0.66 | (16) |

Monitor covers multiple sub-basins

Comments, Assumptions and Unit Values

Exhibit 7

| Assumptions | |
|-------------|--------------------------------------|
| 6.51 | FY 15/16 T&T Cost/1,000 gallons |
| 27 | Average number of days precipitation |

| Note | Comments |
|------|--|
| (1) | removed 3/2/17, used data from 2016 report |
| (2) | installed 3/2/17, used 3/22/17 for AWW, guesstimate on linear feet |
| (3) | installed 3/2/17, used 3/22/17 for AWW, guesstimate on linear feet |
| (4) | inflow reduced |
| (5) | installed 3/2/17, used 3/22/17 for AWW, guesstimate on linear feet |
| (6) | inflow reduced |
| (7) | inflow reduced |
| (8) | inflow reduced |
| (9) | inflow reduced |
| (10) | age, maintenance history, proximity to lake. |
| (11) | Palisades |
| (12) | guesstimate on linear feet |
| (13) | guesstimate on linear feet |
| (14) | 1-01, 1-02, 1-03, 1-04, 1-05, 3-01, 3-02, 3-06 |
| (15) | used same linear feet as GVWWTP |
| (16) | 1-06 / 2-01 / 2-02 / 2-03 / 2-04 / 2-05 / 2-06 / 2-07 / 2-08 / 2-09 / 2-10 / 3-05 / 3-07 / 3-08 / 3-09 / 3-10 / 4-01 / 4-02 / 4-03 / 4-04 / 4-05 / 4-06 / 4-07 |
| (17) | flow data believed to be inaccurate |
| (18) | Sub basin represented by WCTP flow monitor. Monitor covers too large of area to accurately reflect this basin. Further monitoring to be done. |
| (19) | Sub basin represented by GVTP flow monitor. Monitor covers too large of area to accurately reflect this basin. Further monitoring to be done. |